

**State Codes Advisory Committee Meeting**

**Thursday, June 13, 2019**

**10:00 A.M.**

**AGENDA**

**Call to Order.....Bill Duck, Chairman**

**Welcome and Announcements.....Bill Duck**

**Introductions.....Bill Duck**

**Approval of Minutes – February 21, 2019.....Bill Duck**

**Legislative Update.....Ted Miltiades**

**2018 International Fire Code Update Report Final Report.....Dwayne Garriss**

**2018 International Mechanical Code Task Force Final Report.....Elaine Powers**

**Formation of National Electrical Code 2020 Task Force.....Bill Duck**

**Formation of 2018 Permissive Codes Task Force..... Bill Duck**

- **2018 International Property Maintenance Code**
- **2018 International Existing Building Code**

**2018 International Energy Conservation Code Trainings Update.....Jimmy Reynolds**

**Lunch will be provided for SCAC Members and DCA Staff Only!**

**Old Business..... Bill Duck**

**New Business..... Bill Duck**

**Next SCAC Meeting: TBD.....Bill Duck**

**Adjournment.....Bill Duck**



Proposed Amendments (added text to the code is: <u>underlined</u> , deleted text to the code is: <del>struck through</del> )				
ITEM NUMBER	ARTICLE	SUMMARY	PROPONENT	ACTION
IMC-2018-1	Scope	<p>*Add 'Scope' to read as follows:</p> <p><b>SCOPE:</b>                      The provisions of the <i>Georgia State Minimum Standard Mechanical Code</i> shall regulate the design, installation, maintenance, <i>alteration</i> and inspection of mechanical systems that are permanently installed and utilized to provide control of environmental conditions and related processes within buildings. This code shall also regulate those mechanical systems, system components, <i>equipment</i> and appliances specifically addressed herein. The installation of fuel gas distribution piping and <i>equipment</i>, fuel gas-fired appliances and fuel gas-fired <i>appliance</i> venting systems shall be regulated by the <i>Georgia State Minimum Standard Gas Code (International Fuel Gas Code with Georgia Amendments.)</i></p> <p><b>Exception:</b> Detached one- and two-family dwellings and multiple single-family dwellings (townhouses) not more than three stories above grade with separate means of egress and their accessory structures shall comply with <i>Georgia State Minimum Standard One- and Two-Family Dwelling Code (the International Residential Code for One- and Two-Family Dwellings with Georgia State Amendments.)</i></p>	Task Force	R (CF)
IMC-2018-2	Scope	<p>*Add 'Code Reference Guide' as an Exception to 'Scope' as follows:</p> <p><b>Exception:</b> The following table titled 'Codes Reference Guide' establishes specific primary and supplementary code applications and is to be applied by the authority having jurisdiction.</p>	Task Force	A (CF)

\*Note: These amendments are "proposed only" and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

<b>CODES REFERENCE GUIDE</b>		
<b>Area</b>	<b>Primary</b>	<b>Supplement</b>
Occupancy Classification	LSC	IBC
Building Construction Types Including allowable height, allowable building areas, and the requirements for sprinkler protection related to minimum building construction types.	IBC	LSC
Means of Egress	LSC	NONE
Standpipes	IBC	IFC
Interior Finish	LSC	NONE
HVAC Systems	IMC	NONE
Vertical Openings	LSC	NONE
Sprinkler Systems minimum construction standard	LSC	NONE
Fire Alarm Systems	LSC	NONE
Smoke Alarms and Smoke Detection Systems	State Statute and LSC	NONE
Portable Fire Extinguishers	IFC	NONE
Cooking Equipment	LSC and NFPA 96	NONE
Fuel Fired Appliances	IFGC	NFPA 54
Liquid Petroleum Gas	NFPA 58	NFPA 54

\*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

**ACTION:** A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

		Compressed Natural Gas	NFPA 52	NONE		
IMC-2018-3	Scope	The State's minimum requirements for boilers/water heaters and pressure vessels over 200,000 BTU/h (58.61 kW), 210 degrees Fahrenheit or 120 gallons capacity shall be established by O.C.G.A. Title 25, Chapter 15 and the Rules and Regulations of the Office of Insurance and Safety Fire Commissioner.			Task Force	A (CF)
IMC-2018-4	Chapter 1	*Delete Chapter 1 'Administration' without substitution. Chapter 1 to remain in the Code as a reference and guide for local governments in the development of their own <i>Administrative Procedures</i> .			Task Force	A (CF)
IMC-2018-5	202	*Add Definition of 'MAKE-UP AIR' to read as follows:  <b>MAKE-UP AIR.</b> SEE ENVIRONMENTAL AIR			Task Force	A (CF)
IMC-2018-6	301.1	*Revise Section 301.1 'Scope' to read as follows:  <b>301.1 Scope.</b> This chapter shall govern the approval and installation of all equipment and appliances that comprise parts of the building mechanical systems regulated by this code.			Task Force	A (CF)
IMC-2018-7	301.2	*Revise Section 301.2 'Energy utilization' to read as follows:  <b>301.2 Energy utilization.</b> Heating, ventilating and air-conditioning systems of all structures shall be designed and installed for efficient utilization of energy in accordance with the <i>International Energy Conservation Code</i> . Cooling towers installed in new construction shall be in compliance with ASHRAE, Standard 90.1.			Task Force	A (CF)

\*Note: These amendments are "proposed only" and have not been adopted by the Department of Community Affairs.

Page 3 of 13

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-8	301.7	<p>*Revise Section 301.7 ‘ Listed and labeled’ to read as follows:</p> <p><b>301.7 Listed and labeled.</b> Appliances regulated by this code shall be <i>listed</i> and <i>labeled</i> for the application in which they are installed and used, unless otherwise approved.</p> <p><b>Exception</b> to remain unchanged.</p>	Task Force	R (CF)
IMC-2018-9	301.19	<p>*Add new Section 301.19 ‘Related Fire Codes’ to read as follows:</p> <p><b>301.19 Related fire codes.</b> Any reference to the <i>International Fire Code</i> and/or NFPA standards in any chapter of this code shall be to the latest edition as adopted and amended by the Georgia Insurance and Safety Fire Commissioner.</p>	Task Force	A (CF)
IMC-2018-10	306.3	<p>*Revise Section 306.3 ‘Appliances in attics’ to add new Exception #3 to read as follows</p> <p><b>Exceptions:</b></p> <p>3. In Residential Occupancies, attics containing appliances or mechanical equipment service shall be accessible by pull down stairs or other permanent steps and at a minimum be sized to allow the removal of the largest appliance.</p>	Task Force	A
IMC-2018-11	401.7	<p>*Add new Section 401.7 ‘Alternative ventilation procedures’ to read as follows:</p> <p><b>401.7 Alternative ventilation procedures.</b> As an alternative to Chapter 4, the following shall be permitted:</p> <p>1. Ventilation Rate Procedure, Natural Ventilation Procedure or Indoor Air Quality Procedure, as prescribed by ASHRAE 62.1. Software</p>	Task Force	R (CF)

\*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

Page 4 of 13

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

		<p>programs to calculate outdoor ventilation air may be used to demonstrate ASHRAE 62.1 compliance, as approved by authority having jurisdiction.</p> <p>2. ...or a combination of ASHRAE 62.1 and ANSI/ASHRAE/ASHE Standard 170 may be utilized for different occupancy types within a single building.</p>		
IMC-2018-12	501.3	<p>*Revise Section 501.3 'Exhaust discharge' Exception #1 to read as follows:</p> <p>Exceptions:</p> <p>1. Whole-house ventilation-type attic fans shall be permitted to discharge into the ventilated attic space of <i>dwelling units</i> having private attics, provided the installed system meets paragraph 501.4 requirements for pressure equalization.</p>	Task Force	A (CF)
IMC-2018-13	505.3.1	<p>*Add new Section 505.3.1 'Exhaust ducts for domestic range hoods installed in commercial applications' to read as follows</p> <p>505.3.1 Exhaust Ducts for domestic range hoods installed in commercial applications</p> <p>Exhaust ducts for domestic range hoods installed in commercial applications shall be vented to the outside and shall be constructed of (a) Type B vent, or (b) smooth wall duct constructed of galvanized or stainless steel with a minimum duct thickness of 0.0157 inches (0.40 mm) or constructed of aluminum or copper with a minimum duct thickness of 0.023 inches (0.58mm).</p>	Task Force	A

\*Note: These amendments are "proposed only" and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-14	505.7	<p>*Add new Section 505.7 ‘Commercial installations of domestic systems’ to read as follows:</p> <p><b>505.7 Commercial installations of domestic systems.</b> Commercial installations of domestic systems shall comply with the current Life Safety Code NFPA 101 and 96 standards as adopted and amended by the Georgia Insurance and Safety Fire Commissioner.</p>	Task Force	R (CF)
IMC-2018-15	506.1	<p>*Delete Section 506.1 ‘General’ and substitute the following:</p> <p><b>506.1 General.</b> The State’s minimum requirements for Type I commercial kitchen hood ventilation system ducts and exhaust equipment shall be designed, constructed and installed in accordance with the Life Safety Code NFPA 101 and NFPA 96 as adopted and amended by the Georgia Insurance and Safety Fire Commissioner. Other commercial kitchen hood ventilation system ducts and exhaust equipment shall comply with the requirements of this section.</p>	Task Force	R (CF)
IMC-2018-16	507.1	<p>*Delete Section 507.1 ‘General’ and substitute the following:</p> <p><b>507.1 General.</b> The State’s minimum requirements for Type I commercial kitchen hoods shall be designed, constructed and installed in accordance with the Life Safety Code NFPA 101 and NFPA 96 as adopted and amended by the Georgia Insurance and Safety Fire Commissioner. Other commercial kitchen hoods shall comply with the requirements of this section.</p>	Task Force	R (CF)
IMC-2018-17	507.1.2	<p>*Delete Section 507.1.2 ‘Domestic cooking appliances used for commercial purposes’ without substitution.</p>	Task Force	A (CF)

\*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

IMC-2018-18	509.1	<p>*Delete Section 509.1 ‘Where required’ and substitute the following:</p> <p><b>509.1 Where required.</b> The State’s minimum requirements for fire suppression systems for commercial cooking equipment shall be established by the Life Safety Code NFPA 101 and NFPA 96 as adopted and amended by the Georgia Insurance and Safety Fire Commissioner.</p>	Task Force	R (CF)
IMC-2018-19	606.2.1	<p>*Rename Section 606.2.1 ‘Return air systems’ and revise to read as follows:</p> <p><b>606.2.1 Supply air systems.</b> Smoke detectors shall be installed in supply air systems with a design capacity greater than 2,000 cfm(0.9m<sup>3</sup>/s), in the supply air duct downstream of any filters, fan motors, outdoor air connections, and upstream of any branch connections or decontamination equipment and appliances.</p> <p><b>Exception:</b> Smoke detectors are not required in the supply air system where all portions of the building served by the air distribution system are protected by area smoke detectors connected to a fire alarm system in accordance with NFPA 72. The area smoke detection system shall comply with Section 606.4.</p>	Task Force	A (CF)
IMC-2018-20	606.2.2	<p>*Revise Section 606.2.2 ‘Common supply and return air systems’ to read as follows:</p> <p><b>606.2.2 Common supply and return air systems.</b> Where multiple air-handling systems share common supply or return air ducts or plenums with a combined design capacity greater than 2,000 cfm (0.9m<sup>3</sup>/s), the supply air system shall be provided with smoke detectors in accordance with Section 606.2.1.</p> <p><b>Exception:</b> Individual smoke detectors shall not be required for each fan-powered unit, provided that such units do not have an individual design</p>	Task Force	A (CF)

\*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)



		<p>capacity greater than 2,000(0.9m<sup>3</sup>/s) cfm and will be shut down by activation of one of the following;</p> <ol style="list-style-type: none"> <li>1. Smoke detectors required by Sections 606.2.1 and 606.2.3.</li> <li>2. An approved area smoke detector system located in the supply air duct serving such units.</li> <li>3. An area smoke detector system as prescribed in the exception to Section 606.2.1.</li> </ol> <p>In all cases, the smoke detectors shall comply with sections 606.4 and 606.4.1.</p>		
IMC-2018-21	606.4.1	<p>*Revise Section 606.4.1 ‘Supervision’ first sentence to read as follows:</p> <p><b>606.4.1 Supervision.</b> The duct smoke detectors shall be connected to a fire alarm system where a fire alarm system is required by the Life Safety Code NFPA 101 and NFPA 96 as adopted and amended by the Georgia Insurance and Safety Fire Commissioner.</p>	Task Force	A
IMC-2018-22	804.3.8	<p>*Revise Section 804.3.8 ‘Mechanical draft systems for manually fired appliances and fireplaces’ numbers 2 and 3 to read as follows:</p> <p><b>804.3.8 Mechanical draft systems for manually fired appliances and fireplaces.</b>                  #2 A device shall be installed that produces visible and audible warning upon failure of the mechanical draft device or loss of electrical power, at any time that the mechanical draft device is turned on. This device shall be installed in an</p>	Task Force	R (CF)

\*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

		approved location, receive power from the building wiring and equipped with a battery backup. <b>#3</b> A smoke detector shall be installed in the room with the <i>appliance</i> or fireplace. This device shall receive power from the building wiring and equipped with a battery backup.		
IMC-2018-23	908.1	* Revise Section 908.1 ‘General’ to read as follows:  <b>908.1 General.</b> A cooling tower used in conjunction with an air-conditioning appliance shall be installed in accordance with the manufacturer’s installation instructions. Factory-built cooling towers shall be listed in accordance with UL 1995. The standards related to high efficiency cooling towers shall include without limitation the minimum standards prescribed by the ASHRAE, Standard 90.1.	Task Force	A (CF)
IMC-2018-24	917.1	*Revise Section 917.1 ‘Cooking appliances’ to add new Exception to read as follows: <b>Exception:</b> <i>Listed and labeled</i> commercial cooking appliances may be installed in <i>dwelling units</i> and domestic kitchens when such installation is designed by a Georgia Licensed Professional Engineer and accepted by the local authority having jurisdiction.	Task Force	R (CF)
IMC-2018-25	917.2	*Delete Section 917.2 ‘Domestic appliances’ without substitution.	Task Force	A (CF)
IMC-2018-26	1001.1	*Revise Section 1001.1 ‘Scope’ to add the following at the end of first paragraph:	Task Force	R (CF)

\*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

		<b>1001.1 Scope.</b> ...and pressure vessels. The State’s minimum requirements for boilers/water heaters and pressure vessels over 200,000 BTU/h (58.61 kW), 210 degrees Fahrenheit or 120 gallons capacity shall be established by O.C.G.A. Title 25, Chapter 15 and the as adopted and amended Rules and Regulations of the Office of Insurance and Safety Fire Commissioner.		
<b>IMC-2018-27</b>	<b>1105.3</b>	*Renumber Section [F] 1105.3 ‘Refrigerant detector’ as 1105.3 and revise to read as follows:  <b>1105.3 Refrigerant detector.</b> Refrigerant detectors in machinery rooms shall be provided as required in accordance with ASHRAE 15.	Task Force	<b>A (CF)</b>
<b>IMC-2018-28</b>	<b>1106.6</b>	*Renumber Section [F] 1106.6 ‘Remote controls’ as 1106.6 and revise to read as follows:  <b>1106.6 Remote controls.</b> Remote control of the mechanical equipment and appliances located in the machinery room shall be provided as required in accordance with ASHRAE 15.	Task Force	<b>A (CF)</b>
<b>IMC-2018-29</b>	<b>1106.7</b>	*Renumber Section [F] 1106.7 ‘Emergency signs and labels’ as 1106.7 and revise to read as follows:  <b>1106.7 Emergency signs and labels.</b> Refrigeration units and systems shall be provided with <i>approved</i> emergency signs, charts and labels in accordance with ASHRAE 15.	Task Force	<b>A (CF)</b>
<b>IMC-2018-30</b>	<b>1206.8</b>	*Revise Section 1206.8 ‘Steam piping pitch’ to add the following at the end of the paragraph:	Task Force	<b>A (CF)</b>

\*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

**ACTION:** A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

		<b>1206.8 Steam piping pitch.</b> ...the steam piping. Branch piping from steam mains shall be taken off at the top of the pipe.		
<b>IMC-2018-31</b>	<b>1301.1</b>	*Revise Section 1301.1 ‘Scope’ to add the following at the end of the paragraph:  <b>1301.1 Scope.</b> ...International Fire Code. The State’s minimum requirements for fuel oil piping and storage shall be as established by the Georgia State Minimum Fire Safety Standards and the as adopted and amended Rules and Regulations of the Georgia Insurance and Safety Fire Commissioner. Any areas not addressed by the Georgia State Minimum Fire Safety Standards shall be regulated by this chapter.	Task Force	<b>R (CF)</b>
<b>IMC-2018-32</b>	<b>1402.4</b>	*Revise Section 1402.4 ‘Protection from freezing’ to read as follows:  <b>1402.4 Protection from freezing</b> ...at the lowest ambient temperatures that will be encountered. Freeze... (Remainder of paragraph to remain unchanged)	Task Force	<b>A</b>
<b>IMC-2018-33</b>	<b>1403.2.1</b>	*Add new Section 1403.2.1 ‘Protection of drains’ to read as follows:  <b>1403.2.1 Protection of drains.</b> Drains serving heat transfer fluids over 140°F (60°C) or which are toxic or corrosive shall be protected in accordance with the requirements of <i>the International Plumbing Code</i> .	Task Force	<b>A (CF)</b>
<b>IMC-2018-34</b>		*Revise Chapter 15 ‘Referenced Standards’ to add the following:	Task Force	<b>R (CF)</b>

\*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

**ACTION:** A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

		American Society of Heating, Refrigeration and Air Conditioning Engineers, Inc. 1791 Tullie Circle, NE		
		<b>ASHRAE</b>		
		Atlanta,	GA	30329-2305
Standard reference number	Title	Referenced in code section number		
90.1--2016	Energy Standard for Buildings Except Low-Rise Residential Buildings	301.2, 908.1 GA Amendments		
62.1--2016	Ventilation for Acceptable Indoor Air Quality	401.7 GA Amendments		
15--2016	Safety Standard for Refrigeration Systems	1105.3, 1106.6, 1106.7, GA Amendments		
170-2017	Ventilation of Health Care Facilities	401.7, GA Amendments		
		National Fire Protection Association Battery march Park		
		<b>NFPA</b>		
		Quincy, MA 02269		
Standard reference number	Title	Referenced in code section number		
96	Standard for Ventilation and Fire Protection of Commercial Cooking Operations	505.7,506.1, 507.1, 508.509.1, GA Amendments		

\*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

**ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)**

		101	Life Safety Code	506.1, 507.1, 508.1, 509.1 GA Amendments		

DRAFT

\*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

**ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)**