

PROPOSED CODE AMENDMENTS
2023 ERB SUBCOMMITTEE Code Amendments

Proposed Amendments (added text to the code is: <u>underlined</u> , deleted text to the code is: struck through)				
ITEM NUMBER	ARTICLE	SUMMARY	PROPONENT	ACTION
		Proposed		
IECC-2023-4 2023 ERB Amendments submittals and Support P65-67, P76-83		Add a new section beneath the “Residential Provisions” heading in the Georgia State Supplements and Amendments to the International Energy Conservation Code (2015 Edition) as follows: <u>Where required by Georgia State Minimum Standard Energy Code, R6 Flexible Duct combined with an approved continuous Radiant Barrier may be substituted for the required R8 Flexible Duct.</u> <u>The use of this (Exception/substitution) will be valid until June 30th, 2023 at the discretion of the authority having jurisdiction.</u> <u>(Effective September 1st, 2022)</u>	SCAC PMG Subcommittee (Elaine Powers, Chair)	

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)



*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)