

Note Proposed Amendments: (added text to the code is: underlined, deleted text to the code is: ~~struck through~~)

| ITEM | SECTION | SUMMARY | PROPONENT | ACTION |
|-----------------|-----------|--|---|-----------|
| IFGC 2018-01 | Chapter 1 | *Delete Chapter 1 'Scope and Administration' without substitution. Chapter 1 to remain in the Code as a <i>reference and guide</i> for local governments in development of their own <i>Administrative Procedures</i> . | Task Force | A (CF) |
| IFGC 2018-02 | 202 | *Delete the following Section 202 (IFGC) 'General Definitions' without substitution: '[P] THIRD-PARTY CERTIFICATION AGENCY. ' '[P] THIRD-PARTY CERTIFIED. ' '[P] THIRD-PARTY TESTED. ' | Task Force | A (CF) |
| IFGC 2018-03 | 202 | *Revise Section 202 'General Definitions' POINT OF DELIVERY to read as follows: POINT OF DELIVERY. For natural gas systems, the point of delivery is the outlet of the service meter assembly or the outlet of the service regulator or service shutoff valve where a meter is not provided. Where a <u>system shutoff</u> valve is provided at the outlet of the service meter assembly, such valve shall be considered to be downstream of the point of delivery. For undiluted liquefied petroleum gas systems, the point of delivery shall be considered to be the outlet of the service pressure regulator, exclusive of line gas regulators, in the system. | Andrea Papageorge, Task Force Member | A |
| IFGC 2018-04 | 202 | *Revise Section 202 'General Definitions' to add new definition SERVICE METER ASSEMBLY to read as follows: SERVICE METER ASSEMBLY. The meter, valve, regulator, piping, fittings and equipment installed by the service gas supplier before the point of delivery. | Andrea Papageorge, Task Force Member | A |
| IFGC 2018-05 | 202 | *Revise Section 202 'General Definitions' to add new definition System Shutoff to the VALVE sections to read as follows: System Shutoff. A valve installed at the point of delivery to shut off the entire piping system. | Andrea Papageorge, Task Force Member | A |
| IFGC 2018-06 | 300 | *Add new Section 300 (IFGC) 'GENERAL APPLICABILITY STANDARDS' to read as follows: SECTION 300 (IFGC) GENERAL APPLICABILITY STANDARDS 300.1 Scope. This code shall apply to the installation of fuel-gas <i>piping</i> systems, fuel gas appliances, gaseous hydrogen systems and related accessories in accordance with Sections 300.1.1 through 300.1.5. Exception: Detached one- and two-family dwellings and townhouses separated by a 2-hour fire-resistance-rated wall assembly, not more than three stories above <i>grade plane</i> in height with a separate means of egress and their accessory structures shall comply with the <i>Georgia State Minimum Standard One and Two Family Dwelling Code (International Residential Code for One- and Two- Family Dwellings with Georgia State Amendments)</i> 300.1.1 Gaseous hydrogen systems. Gaseous hydrogen systems shall be regulated by Chapter 7. | Task Force | R (CF) |

*Note: These amendments are "proposed only" and have not been adopted by the Department of Community Affairs.

Page 1 of 4

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

Note Proposed Amendments: (added text to the code is: underlined, deleted text to the code is: ~~struck through~~)

| ITEM | SECTION | SUMMARY | PROPONENT | ACTION |
|------|---------|--|-----------|--------|
| | | <p>300.1.2 Piping systems. These regulations cover <i>piping</i> systems for natural gas with an operating pressure of 125 pounds per square inch gauge (psig) (862 kPa gauge) or less, and for LP-gas with an operating pressure of 20 psig (140 kPa gauge) or less, except as provided in Section 402.7. Coverage shall extend from the <i>point of delivery</i> to the outlet of the <i>appliance</i> shutoff valves. <i>Piping</i> system requirements shall include design, materials, components, fabrication, assembly, installation, testing, inspection, operation and maintenance.</p> <p>300.1.3 Gas appliances. Requirements for gas appliances and related accessories shall include installation, combustion and ventilation air and venting and connections to <i>piping</i> systems.</p> <p>300.1.4 Systems, appliances and equipment outside the scope. This code shall not apply to the following:</p> <ol style="list-style-type: none"> 1. Portable LP-gas appliances and <i>equipment</i> of all types that is not connected to a fixed fuel <i>piping</i> system. 2. Installation of farm appliances and <i>equipment</i> such as brooders, dehydrators, dryers and irrigation <i>equipment</i>. 3. Raw material (feedstock) applications except for <i>piping</i> to special atmosphere generators. 4. Oxygen-fuel gas cutting and welding systems. 5. Industrial gas applications using gases such as acetylene and acetylenic compounds, hydrogen, ammonia, carbon monoxide, oxygen and nitrogen. 6. Petroleum refineries, pipeline compressor or pumping stations, loading terminals, compounding plants, refinery tank farms and natural gas processing plants. 7. Integrated chemical plants or portions of such plants where flammable or combustible liquids or gases are produced by, or used in, chemical reactions. 8. LP-gas installations at utility gas plants. 9. Liquefied natural gas (LNG) installations. 10. Fuel gas <i>piping</i> in power and atomic energy plants. 11. Proprietary items of <i>equipment</i>, apparatus or instruments such as gas-generating sets, compressors and calorimeters. 12. LP-gas <i>equipment</i> for vaporization, gas mixing and gas manufacturing. 13. Temporary LP-gas <i>piping</i> for buildings under construction or renovation that is not to become part of the permanent <i>piping</i> system. 14. Installation of LP-gas systems for railroad switch heating. 15. Installation of hydrogen gas, LP-gas and compressed natural gas (CNG) systems on vehicles. 16. Except as provided in Section 401.1.1, gas <i>piping</i>, meters, gas pressure regulators and other appurtenances used by the serving gas supplier in the distribution of gas, other than undiluted LP-gas. 17. Building design and construction, except as specified herein. 18. <i>Piping</i> systems for mixtures of gas and air within the flammable range with an operating pressure greater than 10 psig (69 kPa gauge). 19. Portable fuel cell appliances that are neither connected to a fixed <i>piping</i> system nor interconnected to a power grid. | | |

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

Note Proposed Amendments: (added text to the code is: underlined, deleted text to the code is: ~~struck through~~)

| ITEM | SECTION | SUMMARY | PROPONENT | ACTION |
|-----------------|----------|--|---|-----------|
| | | <p>300.1.5 Other fuels. The requirements for the design, installation, maintenance, <i>alteration</i> and inspection of mechanical systems operating with fuels other than fuel gas shall be regulated by the <i>International Mechanical Code</i>.</p> <p>300.2 Appendices. Appendices are not enforceable unless they are specifically referenced in the body of the code or adopted by the Department of Community Affairs or the Authority Having Jurisdiction.</p> <p>300.3 Intent. The purpose of this code is to provide minimum standards to safeguard life or limb, health, property and public welfare by regulating and controlling the design, construction, installation, quality of materials, location, operation and maintenance or use of fuel gas systems.</p> <p>300.4 Severability. If a section, subsection, sentence, clause or phrase of this code is, for any reason, held to be unconstitutional, such decision shall not affect the validity of the remaining portions of this code.</p> | | |
| IFGC 2018-07 | 404.6 | <p>*Delete Section 404.6 ‘Underground penetrations prohibited’ and substitute to read as follows: 404.6 Piping through foundation wall. Underground piping where installed below grade through the foundation or basement wall of a building, shall be encased in a protective pipe sleeve. The annular space between the gas piping and the sleeve shall be sealed.</p> | Task Force | A (CF) |
| IFGC 2018-08 | 404.7.1 | <p>*Revise Section 404.7.1 ‘Piping through holes or notches’ to read as follows: 404.7.1 Piping through holes or notches. Where piping is installed through holes or notches in framing members and the piping is located less than 1 1/2 inches (38 mm) from the framing member face to which wall, ceiling or floor membranes will be attached, the pipe shall be protected by shield plates that cover the width of the pipe and the framing member. Where the framing member that the piping passes through is a bottom plate, bottom track, top plate or top track, the shield plates shall cover the framing member and extend not less than 4 inches (102 mm) above the bottom framing member and not less than 4 inches (102 mm) below the top framing member.</p> | Windell Peters, Task Force Chairman | A |
| IFGC 2018-09 | 404.7.2 | <p>*Delete Section 404.7.2 ‘Piping installed in other locations’ in its entirety without substitution.</p> | Windell Peters, Task Force Chairman | A |
| IFGC 2018-10 | 404.11.1 | <p>*Delete Section 404.11.1 ‘Galvanizing’ in its entirety without substitution.</p> | Task Force | A (CF) |
| IFGC 2018-11 | 404.18 | <p>*Revise Section 404.18 ‘Pipe cleaning’ to read as follows: 404.18 Pipe <u>cleaning debris removal.</u> The interior of piping shall be clear of debris. The use of a flammable or combustible gas to clean or remove debris from a piping system shall be prohibited.</p> | Task Force | A (CF) |
| IFGC 2018-12 | 406.6.2 | <p>*Revise Section 406.6.2 ‘Before turning gas on’ heading to read as follows: 406.6.2 Turning gas on. (Remainder of section unchanged)</p> | Windell Peters, Task Force Chairman | A |

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

Page 3 of 4

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)

Note Proposed Amendments: (added text to the code is: underlined, deleted text to the code is: ~~struck through~~)

| ITEM | SECTION | SUMMARY | PROPONENT | ACTION |
|-----------------|--------------------------------------|--|---|-----------|
| IFGC 2018-13 | 412 | *Delete Section 412 ‘Liquefied Petroleum Gas Motor Vehicle Fuel-Dispensing Facilities’ and substitute to read as follows: 412.1 General. Under Georgia law, the Rules and Regulations of the Georgia Safety Fire Commissioner’s Office govern the storage, delivery and dispensing of Liquefied Petroleum Gas. Refer to the Rules and Regulations of the Georgia Safety Fire Commissioner’s Office and NFPA 58 <u>as adopted and amended</u> for all requirements concerning liquefied petroleum gas motor vehicle fuel-dispensing facilities. | Windell Peters, Task Force Chairman | A |
| IFGC 2018-14 | 413 | *Delete Section 413 ‘Compressed Natural Gas Motor Vehicle Fuel-Dispensing Facilities’ and substitute to read as follows: 413.1 General. Under Georgia law, the Rules and Regulations of the Georgia Safety Fire Commissioner govern the storage, delivery and dispensing of compressed natural gas. Refer to the Rules and Regulations of the Georgia Safety Fire Commissioner and NFPA 52 <u>as adopted and amended</u> for all requirements concerning compressed natural gas motor vehicle fuel-dispensing stations | Windell Peters, Task Force Chairman | A |
| IFGC 2018-15 | 624.3 | *Add new Section 624.3 ‘Boilers/water heaters’ to read as follows: 624.3 Boilers/water heaters. The State’s minimum requirements for boilers/water heaters and pressure vessels over 200,000 BTU/h (58.61 kW), 210 degrees Fahrenheit or 120 gallons capacity shall be established by O.C.G.A. Title 25, Chapter 15 and the Rules and Regulations <u>as amended and adopted</u> of the Georgia Safety Fire Commissioner. | Task Force | R (CF) |
| IFGC 2018-16 | 631.4 | *Add new Section 631.4 ‘Additional regulations’ to read as follows: 631.4 Additional regulations. For additional regulations regarding boilers/water heaters, see Section 624.3 (GA Amendments). | Task Force | A (CF) |
| IFGC 2018-17 | Chapter 8 Referenced Standards | *Revise reference standard to read as follows: LC 1/CSA 6.26---201318: Fuel Gas Piping Systems Using Corrugated Stainless Steel Tubing (CSST) 403.5.5 | Jonathan Sargeant, Omega Flex | A |
| | | End of Report | | |

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.

ACTION: A (Approve as Submitted); R (Approve as Revised); D (Disapprove); W (Withdrawn); CF (Carry Forward)