

Note Proposed Amendments: (added text to the code is: underlined, deleted text to the code is: ~~struck through~~)

ITEM	SECTION	SUMMARY	PROPONENT	ACTION
NEC 2020-01	210.8	*Revise Section 210.8(A)(7) to add a new exception to read as follows: <u>Exception: Single type dedicated kitchen appliance receptacles may be not be required to be GFCI protected. Where the dedicated receptacle is identified, a label must be permanently mounted at the panel box and at the outlet.</u> Motion: Bob Barnard to disapprove 2 nd : Bill Edler Result: Unanimous by consent agenda	MAIA	D
NEC 2020-02	210.8	*Revise Section 210.8(A)(7) to add a new exception to read as follows: <u>Exception: Single type dedicated refrigerator appliance receptacles may be not be required to be GFCI protected. Where the dedicated receptacle is identified, a label must be permanently mounted at the panel box and at the outlet</u> Motion: Bob Barnard to approve (motion died due to lack of a second), Roger McDaniel to disapprove 2 nd : Bill Edler Result: Passed 7 to 1 (Bob Barnard neigh)	MAIA	D
NEC 2020-03	210.8	*Revise Section 210.8(A)(7) to add a new exception to read as follows: <u>Exception: Single type refrigerator appliance receptacles may be not be required to be Arc-fault nor GFCI protected. Where the exempted receptacle is identified, a label must be mounted at the panel box and at the outlet.</u> Motion: Bob Barnard to disapprove 2 nd : Roger McDaniel Result: Unanimous by consent agenda	BOAG	D
NEC 2020-04	210.12	*Revise Section 210.12(A) to add a new exception to read as follows: <u>Exception: Refrigerator appliance receptacles located behind the refrigerator/freezer shall be on a dedicated circuit that shall not be required to be AFCI (Arc-fault) protected. Where the exempted receptacle is identified, a label must be mounted at the panel box and at the outlet.</u> Motion: Jerry Wainright to disapprove 2 nd : Roger McDaniel Result: Passed 7 to 1 (Bob Barnard neigh)	HBAG	D
NEC 2020-05	210.52	*Revise Section 210.52(A)(4) ‘Countertop and Similar Work Surface Receptacle Outlets’ to read as follows: (4) Countertop and Similar Work Surface Receptacle Outlets. Receptacles installed for countertop and similar work surfaces as specified in 210.52(C) shall not be considered as the receptacle outlets required by 210.52(A), <u>unless installed in accessible countertops in Meeting Rooms as defined by 210.65.</u> Motion: Roger McDaniel to disapprove 2 nd : Bill Edler Result: Unanimous by consent agenda	AIA Georgia	D
NEC 2020-06	230.67	*Discussion point: Delay Implementation of Section 230.67 ‘Surge Protection’ until the next code cycle. Motion: no motion 2 nd : Result:	HBAG	

*Note: These amendments are “proposed only” and have not been adopted by the Department of Community Affairs.