



Georgia State Amendments to the International Fuel Gas Code (2018 Edition)



Georgia Department of Community Affairs
Community Development Division
60 Executive Park South, N.E.
Atlanta, Georgia 30329-2231
(404) 679-3118
www.dca.ga.gov

Revised January 1, 2022

**GEORGIA STATE MINIMUM STANDARD GAS CODE
(INTERNATIONAL FUEL GAS CODE WITH GEORGIA STATE AMENDMENTS)**

The **INTERNATIONAL FUEL GAS CODE, 2018 Edition**, published by the International Code Council, when used in conjunction with these and any other Georgia State Amendments to the **INTERNATIONAL FUEL GAS CODE, 2018 Edition**, shall constitute the official *Georgia State Minimum Standard Gas Code*.

GEORGIA STATE AMENDMENTS

CODE REFERENCE:

- (a) Replace all references to the ICC *Electrical Code* with references to the *Georgia State Minimum Standard Electrical Code (National Electrical Code with Georgia State Amendments)*.

**Revise the International Fuel Gas Code, 2018 Edition, to read as follows:*

**CHAPTER 4
GAS PIPING INSTALLATIONS**

**SECTION 409 (IFGC)
SHUTOFF VALVES**

*Add new Section 409.2.1 'System shutoff valve' to read as follows:

409.2.1 System shutoff valve. Where the point of delivery is the outlet of the service meter assembly, or the outlet of the service regulator, a system shutoff valve shall be installed. Such valve is considered to be part of the customer piping system.
(Effective January 1, 2022)

End of Amendments.

Authority: O.C.G.A. § 8-2-20 et seq.