



Georgia State Amendments to the International Fuel Gas Code (2006 Edition)



Georgia Department of Community Affairs
Planning and Environmental Management Division
60 Executive Park South, N.E.
Atlanta, Georgia 30329-2231
(404) 679-3118
www.dca.state.ga.us

Revised January 1, 2008

**GEORGIA STATE MINIMUM STANDARD
GAS CODE
(INTERNATIONAL FUEL GAS CODE
WITH GEORGIA STATE AMENDMENTS)**

The **INTERNATIONAL FUEL GAS CODE, 2006 Edition**, published by the International Code Council, when used in conjunction with these Georgia State Amendments and the Georgia State Amendments adopted effective January 1 of 2007, shall constitute the official *Georgia State Minimum Standard Gas Code*.

GEORGIA STATE AMENDMENTS

CODE REFERENCE:

Replace all references to the ICC *Electrical Code* with references to the *Georgia State Minimum Standard Electrical Code (National Electrical Code with Georgia State Amendments)*.

**Revise the International Fuel Gas Code, 2006 Edition, as follows:*

**CHAPTER 3
GENERAL REGULATIONS**

**SECTION 310 (IFGS)
ELECTRICAL BONDING**

*Add new Section 310.1.1, 'Bonding Corrugated Stainless Steel Tubing (CSST)', as follows:

310.1.1 Bonding Corrugated Stainless Steel Tubing (CSST). Corrugated stainless steel tubing shall be directly bonded to the electrical grounding system. The direct bonding connection shall be made with American Wire Gauge (AWG) number 6 copper wire. The copper wire shall be attached to either the CSST fitting or to a segment of rigid piping component connected to a fitting located near the electrical meter using an approved bonding clamp in accordance with the CSST manufacturer's installation instructions. The bonding conductor shall be affixed to either the grounding conductor or electrode using an approved clamp or other approved means of attachment.

(Effective January 1, 2008)

End of Amendments.