



Georgia State Amendments to the International Fuel Gas Code (2006 Edition)



Georgia Department of Community Affairs
Local Government Assistance Division
60 Executive Park South, N.E.
Atlanta, Georgia 30329-2231
(404) 679-3118
www.dca.ga.gov

Revised January 1, 2012

**GEORGIA STATE MINIMUM STANDARD
GAS CODE
(INTERNATIONAL FUEL GAS CODE
WITH GEORGIA STATE AMENDMENTS)**

The **INTERNATIONAL FUEL GAS CODE, 2006 Edition**, published by the International Code Council, when used in conjunction with these Georgia State Amendments and all other Georgia State Amendments to the **INTERNATIONAL FUEL GAS CODE, 2006 Edition**, shall constitute the official *Georgia State Minimum Standard Gas Code*.

GEORGIA STATE AMENDMENTS

CODE REFERENCE:

Replace all references to the ICC *Electrical Code* with references to the *Georgia State Minimum Standard Electrical Code (National Electrical Code with any Georgia State Amendments)*.

***Revise the International Fuel Gas Code, 2006 Edition, as follows:**

**CHAPTER 4
GAS PIPING INSTALLATIONS**

**SECTION 408 (IFGC)
DRIPS AND SLOPED PIPING**

*Revise Section 408.4 'Sediment trap' to read as follows:

408.4 Sediment trap. Where a sediment trap is not incorporated as part of the appliance, a sediment trap shall be installed downstream of the appliance shutoff valve as close to the inlet of the appliance as practical. The sediment trap shall be either a tee fitting having a capped nipple of any length installed vertically in the bottommost opening of the tee as illustrated in Figure 408.4 or other device approved as an effective sediment trap. Illuminating appliances, ranges, clothes dryers, decorative vented appliances for installation in vented fireplaces, gas fireplaces, and outdoor grills need not be so equipped.

(Effective January 1, 2012)

*Add new Figure 408.4 'SEDIMENT TRAP.'

See page 3.

(Effective January 1, 2012)

End of Amendments.

